

3.2.2. Fixed extinguishing installations – Automatic Fire Extinguishing

The components have to be in conformity with the standards listed in the table underneath.

The components for which the table does not mention an applicable standard, the rule is that they have to be in conformity with the standards specified in the project studies (EN, CEA, NFPA, FM, NTN ANPI, etc.). If a European standard is published it becomes mandatory and replaces the other specifications.

In all cases the traceability (through marking) of all the elements of the Installation has to be guaranteed.

NORMES/STANDARDS/NORMEN	COMPOSANTS/COMPONENTS/ COMPONENTEN	DATE/ DATUM	Ed.
EN 12094-1 + NTN EN12094-1	Electrical control and delay devices	2003 2006	1
EN 12094-3	Manual triggering and stop devices	2003	
NTN 123-2	Control cabinets for diesel motor pump units	2015	
NTN 123-3	Control cabinets for electric motor pump units	2015	
NTN 112	Fixed extinguishing modules for boilers	2009	3
NTN 113	Fixed extinguishing modules for fryers	2008	3