



CERTIFICATE

B - 9173 - FD - 931 - version a

We certify that the fire detection system with the following components:

Fire control panel with integrated power supply equipment

Type: Firedex FX2201/B with 1 zone

Variants: FX2202 & FX2202/B (with 2 zones), FX2204 & FX2204/B (with 4 zones), FX2208 & FX2208/B (with 8 zones) and CF CF100/CX100 with 1 zone, CF200/CX200 with 2 zones, CF400/CX400 with 4 zones & CF800/CX800 with 8 zones

Manufactured at Dongguan (P.R. China)

Multisensor detector (type C according CEA 4021)

Type: Menvier MPT951

Variants: Cooper CPT341, CPTB341 and JSB FXN632

Manufactured at Dongguan (P.R. China)

Base

Type: Menvier MDB800

Variants: Cooper CDB300, CDBB300 and JSB FXN520

Manufactured at Dongguan (P.R. China)

complies with the following specifications:

BOSEC Mark Rules: Administrative and Legal Clauses & Certification rules Products;

EN 54-2:1997/A1:2006;

EN 54-4:1997/A1:2002/A2:2006;

EN 54-5:2000/A1:2002;

EN 54-7:2000/A1:2002/A2:2006;

based upon the test report of the laboratories ANPI, EC(CPD) Certificate(s) of conformity & Certificate(s) of Constancy of Performance (CPR):

BFS/DE/1099 - Add.2 - 2005.12.08, Add. 3 - 2005.12.20, Add. 6 - 2006.05.29, Add. 7 - 2008.03.26 & Add. 8 - 2008.10.20, BFS/REDI/242-2009.11.26 & 1134-CPD-076-26/11/2009, 0832-CPD-0629-05/08/2011, 0832-CPD-0628-05/08/2011.

*This certificate is only valid if the products are marked with the **BOSEC** label.*

The company

Eaton Electrical Systems Ltd

Wheatley Hall Road

Doncaster

South Yorkshire DN2 4NB

United Kingdom

*is authorised to use the brand **BOSEC** on the above mentioned components. An instruction manual shall be provided with each detector*

The certificate is granted subject to the BOSEC brand committee and ANPI terms and conditions and is valid until

31 August 2022

signed on behalf of **ANPI**
Brussels, 22 January 2020


Secretary-General

asbl **ANPI** vzw - Association Nationale pour la Protection contre l'Incendie et l'Intrusion

Parc scientifique Fleming - Granbonpré 1 B-1348 Louvain-La-Neuve

Tél: +32 10 47 52 11 Fax: +32 10 47 52 70 cert@anpi.be www.anpi.be





Annex 1 to the certificate B - 9173 - FD - 931 - version a

The certificate takes into account for the Control and Indicating Equipment with the optional functions of the EN54-2/A1:2006 (options with requirements):

7.8	Output to fire alarm devices (output to C)
10.1	General requirements
10.2	Indication of the test condition
10.3	Indication of zones in the test state

**This annex is an undivided part of the
BOSEC certificate and is valid until**

31 August 2022

signed on behalf of **ANPI**
Brussels, 22 January 2020

Secretary General

asbl **ANPI** vzw - Association Nationale pour la Protection contre l'Incendie et l'Intrusion
Parc scientifique Fleming - Granbonpré 1 B-1348 Louvain-La-Neuve
Tél: +32 10 47 52 11 **Fax:** +32 10 47 52 70 cert@anpi.be www.anpi.be



This certificate and the annexes may only be copied completely and without any alteration.